



NEWTROL-C

AMINE STEAM LINE TREATMENT

DESCRIPTION:

Newtrol-C is a volatile amine that effectively neutralizes carbonic acid in condensate systems. Corrosion protection is achieved by adjustment of pH into the neutral to slightly alkaline zone. Buffering the pH prevents the carbonic acid from corroding the return piping and bringing the corrosion products back to the boiler.

APPLICATION AND DOSAGE:

Newtrol-C is best fed continuously to the boiler steam header or feed water tank when necessary. Sufficient Newtrol C should be used to maintain a pH of 8.4 - 9.4 in the condensate.

PRODUCT DATA:

FORM:	Liquid	FLASH POINT:	62 Degrees C
pH:	12.7	FREEZE POINT:	-14 Degrees C
SPECIFIC GRAVITY: 1.0 g/L			

GOVERNMENT APPROVALS:

Newtrol c has received a Letter of No Objection from the Canadian Food Inspection Agency (CFIA) for use in food facilities, provided that it is used in keeping with the instructions outlined on the label. *CF/A designated W1 Approved.*

HANDLING:

Avoid contact with skin and eyes. Harmful if swallowed. Do not breathe vapors. If contacted, flush skin and/or eyes with large quantities of water. Get medical attention. Refer to Safety Data Sheets for specific instructions.

RED DEER (head office):

155 Queens Drive
Red Deer, AB, T4P 0R3

Local: 403-346-8787
Toll Free: 1-800-997-4899
Fax: 403-346-7779

PACIFIC DIVISON:

Unit 69, 1833 Coast Meridian
Road, Port Coquitlam
BC, V3C 6G5

Local: 604-855-8797

CALGARY:

7212 Flint PI SE
Calgary,
AB, T2H 1Y8

Local: 403-265-5055

NISKU:

1807, 5th Street
Nisku,
AB, T9E 7V7

Local: 780-955-7787

GRANDE PRAIRIE:

3416-109 Street
County of Grande Prairie No. 1
AB, T8W 5B5

Local: 780-933-8550